

By Speed Post/FAX

PRASAR BHARTI (BCI)
DIRECTORATE GENERAL: DOORDARSHAN
DOORDARSHAN BHAVAN, COPERNICUS MARG,
NEW DELHI – 110 001.

F. No 1 (3) 2008-09-EI-P (TV)

Dt. 20.07.2009

To,

M/s -----

Subject: Procurement of 500W (1+1) Auto Mode VHF and UHF LPTs.

Dear Sir,

The following Amendment to the specification no. DD/Tx/500W LPT (1+1)E-V/2008 dt.26.02.2009 is here by authorized.

Para No.	Existing DD Specification	To be replaced as
BOM 3.3	6KVA ONLINE UPS with sealed Maintenance Free batteries for Half hour backup at full load. Emerson Liebert/Mitsubishi/Merlin Gerin/Gutor/APC/Sukam make)	6KVA ONLINE UPS with sealed Maintenance Free batteries for Half hour backup at full load. Emerson Liebert/Mitsubishi/Merlin Gerin/Gutor/APC/APLAB/Sukam or similar reputed make)

This is however without any commitment whatsoever at this stage.

Yours faithfully



Preminder Singh
(Assistant Engineer)
For Director General
Tele/ Fax 23387620

E-mail: - ddpurchase401@yahoo.co.in

Copy for kind information

DE(RS)